

Equipment Description	Building Area Served	Equipment Manufacturer	Equip Model Number	Equip Serial Number	Capacity/Size
RTAF 215EUA Air-Cooled / Screw Compressor Chiller Unit	Building Chilled water Loop	Trane	RTAF 215E UAKH XUA1 N23X 1NXN CCV1 HBXB XXXA A1XX XX0	U22M05374	215 Nominal Tons
Chiller Water Make-up System + Pump	Building Chilled water Loop	A.O. Smith	S48C08C09	8F97	.333 HP
Atmospheric Hot Water Boilers / Modular (7)	Building Heating Loop	Hydrotherm	MR-2100-B-PV	MSM2359	2100 mbh
Atmospheric Hot Water Boilers / Modular (7)	Building Heating Loop	Hydrotherm	MR-2100-B-PV	MSM2358	2100 mbh
Hot Water Boiler Control Panels (2)	Floors 1,2,3 & 4	Heat-Timer Corporation	SQ-Elite-8T & SQ-Ext	SQ8T1647515631 / DO4SQEXR002	
Steam Humidifier / 1st Fl	AHU-1	Armstrong	GFH-300	B357859C-1-1	420 mbh
Steam Humidifier / 4th Fl	AHU-2	Armstrong	GFH-300	B357858C-1-1	420 mbh
AHU-1 Supply Air Fan.	Floors 1 & 2	McQuay	CAH065FDAC	SCOU3300444	60 hp
EF-1 Return Air Fan.	Floors 1 & 2	Greenheck	36TC5	99H21273	30 hp
AHU-2 Supply Air Fan.	Floors 3 & 4	McQuay	CAH065FDAC	SCOU3300445	60 hp
EF-2 Retrun Air Fan.	Floors 3 & 4	Greenheck	36TC5	99H21272	30 hp
P3 / Base Mounted Pump	Chilled Water Loop	Bell & Gossett	1510 / 5BC 7.75 BF	2174932	15 hp
P4 / Base Mounted Pump	Chilled Water Loop	Bell & Gossett	1510 / 5BC 7.75 BF	2174933	15 hp
P1 / Base Mounted Pump	Heating Water Loop	Bell & Gossett	1510 / 2.5BB 7.750 BF	2176244	7.5 hp
P2 / Base Mounted Pump	Heating Water Loop	Bell & Gossett	1510 / 2.5BB 7.750 BF	2176245	7.5 hp
P5A / In-Line Pump	Boiler Loop	Bell & Gossett	80 / 4x4x7 6.750BF	2185335	5 hp
P5B / In-Line Pump	Boiler Loop	Bell & Gossett	80 / 4x4x7 6.750BF	2185336	5 hp
P6 / In-Line Pump.	AHU 1	Bell & Gossett	80 / 3x3x7B 5.875BF	2185340	1.5 hp
P7 / In-Line Pump.	AHU 2	Bell & Gossett	80 / 3x3x7C 5.875BF	87211L81L18	1.5 hp
Fan Powered Boxes (29)	Ceiling accessible / all floors	Price Industries	FDC Series / Various	Various	Various
VAV Boxes (38)	Ceiling accessible / all floors	Price Industries	FDC Series / Various	Various	Various
Roof Mounted Exhaust Fans (7)	Restroom TE-1 North	Dayton Electric	4YC72H	15206938 17J	.333 HP direct
	Restroom TE-2 South	Dayton Electric	5DVTO	15247535 17K	.25 hp direct
	Garage	Greenheck	RBE-H20-5		.50 hp belt
	Canvas EF-1 South	Greenheck	CUE-100HP-4-VG-1-19-X	24852811 24F	.25 hp direct
	Canvas EF-2 North	Greenheck	CUE-100HP-4-VG-1-19-X	24852812 24F	.25 hp direct
	Atrium SEF-1 North	Greenheck	RBE-3H72-75	99H19352	7.5 hp belt
	Atrium SEF-2 South	Greenheck	RBE-3H72-75	99H19353	7.5 hp belt

Equipment Description	Building Area Served	Equipment Manufacturer	Equip Model Number	Equip Serial Number	Capacity/Size
Hanging HW unit Heaters (5)	Garage North / UH-1	Airtherm	HU-45	8817206	.05 hp
	Garage South / UH-2	Airtherm	HU-45	8817206	.05 hp
	NW Corner / inside 2nd Fl Overhang / UH-3.	Trane	S Series		.05 hp
	NW Corner / inside 2nd Fl Overhang / UH-4.	Trane	S Series		.05 hp
	NE Corner / inside 2nd Fl Overhang / UH-5.	Trane	S Series		.05 hp
Electric Baseboard Heaters (33)	1st floor halls/lobby perimeter - floors 2,3,4 janitors closets	Berko / Marley	ASL3 Series	Various	208 volt
Electric Duct Heater Coil / VAV1.8	1st floor supply room	PM Wright	SC-CTPX	336390-001	208V / 14.2 AMP
Elect. Wall Mounted Cabinet Heaters (8)	Rear SE Stairway Floor 1 / CUH-2	Marley / 900 series	CUH93503201FF	0300 325	10.236 mbh
	Rear SE Stairways Floor 2 / CUH-4	Marley / 900 series	CUH93503201FF	0300 329	10.236 mbh
	Rear SE Stairway Floor 3 / CUH-6	Marley / 900 series	CUH93503201FF	0300 330	10.236 mbh
	Rear SE Stairways Floor 4 / CUH-8	Marley / 900 series	CUH93503201FF	0300 328	10.236 mbh
	Rear SW Stairway Floor 1 / CUH-1	Marley / 900 series	CUH93503201FF	0300 324	10.236 mbh
	Rear SW Stairways Floor 2 / CUH-3	Marley / 900 series	CUH93503201FF	0300-326	10.236 mbh
	Rear SW Stairways Floor 3 / CUH-5	Marley / 900 series	CUH93503201FF	0300 327	10.236 mbh
	Rear SW Stairways Floor 4 / CUH-7	Marley / 900 series	CUH93503201FF	0300 331	10.236 mbh
Elect. / Hanging Unit Heaters (5)	West Hall - North end	Berko / Marley	HUHAA1048	none	34.12 mbh
	West Hall - South end	Berko / Marley	HUHAA1048	none	34.12 mbh
	Receiving	Qmark	MUH0521MG	none	12.6 to 17 mbh
	S/W Staff Ent.	Berko / Marley	HUHAA748	none	25.59 mbh
	1st Floor Mech Rm.	Berko / Marley	HUHAA2548	none	85.2 mbh
Elect / Hanging Heated Air Curtain	North Main Ent.	Mars	LPV272-1EBF-OB	1032302	32.414 mbh
Split System Heat Pump / Evaporator Unit	4th floor IT server Room	Mitsubishi Electric	PKA-A36KA7	04M02164	3 hp
Roof Mounted Condenser Unit	4th floor IT server Room	Mitsubishi Electric	PUY-A36NKA7	16U22006C	3 Nominal Tons