

Addendum:

1. All offices, meeting rooms, etc. are to have basket style recessed troffer fixtures (2 X 2 & 2 X 4). Are these fixtures as discussed at our pre-bid meeting on October 1, to be completely new Led fixtures, and not a retrofit kits? My notes from the meeting state that all new fixtures where ever possible.
 - a. Yes, all new LED fixtures wherever possible.

2. Building Exterior 10" recessed can light fixtures. Should these be completely new Led recessed can lights kits in lieu of Led lamps. There are a few very good manufactures that sell Led replacements for these, and some that come with a 10 year warranty.
 - a. As above, all new LED fixtures wherever possible.